



SECTION VIEW

Supply line may enter trough from above ground or through tank floor. For above ground installation, protect the pipe from livestock and/or cold weather damage. Maximum diameter of supply line shall be 1 inch. All pipe and fittings shall be schedule 40 galvanized metal.

DIMENSIONS

D = _____ ft
H = _____ ft
_____ gallons

Drawing not to scale. Standardized drawings must be adapted to the specific site.

U.S.D.A. NATURAL RESOURCES CONSERVATION SERVICE	JOB CLASS _____	Date _____
	CAD FILE NO. LSK-0155.DWG	Designed _____
	SHEET _____ OF _____	Drawn _____
		Checked _____
	Approved _____	